



NOTE: 1) HYDRO TEST @ 260 PSIG. MIN.

HEADS	LEFT - .245" SA-455 2:1 S.E.	48-HA-1060-W	REV. 11-21-02
	(.223" MIN.) JOGGLE		DATE: 6-19-92
	RIGHT - .3125" SA-516-70 2:1 S.E.		FOR: HANSON STANDARD
	(.288" MIN.) JOGGLE		HORIZ. AIR TANK.
SHELL	.288" SA-455	INSIDE: UNPAINTED	
	M.A.W.P. 200 PSIG. @ 400 °F	OUTSIDE: PRIME	
	M.D.M.T. -20 °F 200 PSIG.	CAD-"B" SIZE UNDER "STD"-SERIES	
	ASME. SECTION VIII DIV. 1, 2001	BY: J.G.   SCALE: 3/4"=12"	
	X-RAY: RT-4 SPOT L.S. & LEFT G.S.	<b>ROY E. HANSON JR. MFG.</b>	
	GALLONS: 1060   WT. 2159 LBS.	1924 COMPTON AVE.	
	SERIAL NO.	LOS ANGELES, CA 90011	
	N.B.		